

Test Verification of Conformity

Verification Number: 103656887GRR-001bV

On the basis of the tests undertaken, the sample of the below product has been found to comply with the requirements of the referenced specification/standard at the time the tests were carried out. This verification is part of the full test report and should be read in conjunction with it.

Applicant Name & Address:	Steve Loftis NCFI Polyurethanes, Division of Barnhardt Mfg. Co. 1515 Carter Street Mount Airy, NC 27030 USA
Product Description:	11-017 Closed Cell Spray Polyurethane Foam
Ratings & Principle Characteristics:	CDPH 01350: This product conforms to formaldehyde and individual VOC requirements specified in California Department of Public Health CDPH/EHLB/Standard Method Version 1.2, 2017 Table 4-1 for the School Classroom, Private Office, and Single-family Residence scenarios as defined in Tables 4-3, 4-5, and B-2 respectively for wall, ceiling, and ceiling + wall applications. LEED v4: Indoor air concentrations for TVOCs are < 0.5 mg/m ³ for wall applications. Concentrations are between 0.5 and 5.0 mg/m ³ for ceiling and for School Classroom ceiling + wall applications. Concentrations are > 5.0 mg/m ³ for Single-family Residence ceiling + wall applications.
Models/Type References:	11-017 Closed Cell Spray Polyurethane Foam
Brand Name:	NCFI Polyurethanes
Specification / Standard:	California Department of Public Health CDPH/EHLB/Standard Method Version 1.2, 2017
Verification Issuing Office Name & Address:	Intertek 4700 Broadmoor Ave SE; Suite 200 Kentwood, MI 49512
Test Report Number:	103656887GRR-001b



Signature

Name: Amanda Tongen

Position: Chemist

Date: 25-October-2018